

PRODUCT DATASHEET

2HB12-50JPLR

DragonSkin 1/2" Fire-Resistant UL 2196 Certified Standalone Coaxial Cable, Meets NFPA 72 & NFPA 1221 Survivability, Maintains In-Building Communications During Fires, Made in the USA

This standalone coaxible cable is certified to meet the UL 2196 Standard for Fire Test for Circuit Integrity of Fire-Resistive Power, Instrumentation, Control and Data Cables. Visit the DragonSkin Cable Website: www.dragonskincable.com

FEATURES / BENEFITS

 First UL Listed standalone communications cable meeting NFPA 72 and 1221 survivability standard

Verifies the cable survives 2 hours at temperatures up to 1,850 degrees F and the water spray test without conduit or additional wrapping

• Enables cellular and public safety radio communications to and from all floors of a burning building

Ensures emergency responders and building occupants have reliable access to communcations during fires

No conduit or cable wrapping required

Reduces cable size and weight; simplifies installation

CATVP plenum-certified

TMeets certification for use in the environmental air handling space in buildings

· Coaxial cable features solid inner and outer conductors

Virtually eliminates intermodulation

· Maintains minimum bending radius at all times

Accelerates installations, especially in smaller spaces and older buildings

Uses standard RFS connectors and installation techniques

Eliminates the need for specialized parts or expertise

Review the Complete DragonSkin Technical Specifications



Technical features

STRUCTURE

Size

| Jacket Option | | Plenum-Rated, Color Red |
|--|--|---|
| Cable Type | | Air-Dielectric, Corrugated |
| TESTING AND ENVIRONMENTAL | | |
| Flame Retardant Jacket Specifications | | Meets/Exceeds Steiner Tunnel Test Method NFPA-262. NEC820-53 (a), CATVP, UL2196 (2hours) |
| Regulatory Compliance | | NEC Article 820 CATVP Cable to UL1655, Circuit integrity UL Listed to UL2196, CATVP, NFPA-262, NFPA130, NFPA 72, NFPA 1221 2019 (section 5.5.1.1), Canadian CSA C.22.2/FT6, UL R40176, E239351, UL System FHIT 1250 |
| External Document Links | | |

Notes

1/2

2HB12-50JPLR REV : F REV DATE : 16 Dec 2021 WWW.rfstechnologies.com